

# AAMA SHEET

Job Name: AAMA 2604

NOTE: ALL APPLICATOR INFORMATION MUST BE PROVIDED PPG Salesperson: KRISTIN BARTLETT  
AND TESTS SUCCESSFULLY COMPLETED BEFORE  
WARRANTY WILL BE ISSUED. WARRANTIES MUST BE  
REQUESTED IN WRITING AT TIME OF TEST SUBMISSION.

PPG INDUSTRIES, INC., 125 COLFAX STREET, SPRINGDALE, PENNSYLVANIA, 15144 PHONE (724) 274-  
7900 FAX (724-274-3837)

INDUSTRIAL FINISHES LAB

ATTENTION: AAMA TESTING

## PRODUCTION TESTING - EXTRUSION COATINGS

**APPLICATOR:** ULTRA ALUMINUM **LOCATIO** HOWELL, MI  
**PRODUCT:** PCSZ29113 **BATCH NUMBER :** NOT PROVIDED  
**QUALIT** POWDER **PRODUCTION DATE**  
**SURFACE PREPARATION &** PHOSPHATE CONVERSION  
**BAKE SCHEDULE :** 17@380 METAL TEMP **PRIMER CODE :** NA  
**CLEAR BATCH NUMBER :** NA

## AAMA SPECIFICATION TESTING

**PENCIL HARDNESS** 3H **DRY FILM THICKNESS :** 2.5 MILS  
**DRY CROSSHATCH ADHESION :** PASS **WET CROSSHATCH ADHESION :** PASS  
**BOIL CROSSHATCH ADHESION :** PASS **KNIFE ADHESION :** NA  
**60 GLOSS :** 83.6 **ACID TEST :** PASS **DETERGENT TEST :** PASS  
**MORTAR TEST:** PASS **CURE TEST :** PASS  
**1500 SS SCRIBE RATE :** **1500 SS BLISTER RATE :** **1500 HUMIDITY :**  
**3000 SS SCRIBE RATE :** 10 **3000 SS BLISTER RATE** 10 **3000 HUMIDITY :** PASS  
**4000 SS SCRIBE RATE** **4000 SS BLISTER RATE :** **4000 HUMIDITY :**  
**WITH IN " AAMA " SPECIFICATIONS :** PASSED TESTING  
**FAILED " AAMA " SPECIFICATIONS :**

**REMARKS**  
:

RETURN  
PARTS  
TO  
KRISTIN.

**REPORTED BY :** AAMA/TDV**COMPLETION DATE :** 5/29/2008